## sudburyn suomalainen lepokotiyhdistys

| Manual: Emergency Measures        | Policy Number: EM-DS-01                          |
|-----------------------------------|--|
| -                                 | Policy Name: Disruption Of Services Introduction |
| Document Owner:                   | Page: 1 of 1                                     |
| Effective Date: December 20, 2016 | Revised: June 2, 2022                            |

Red plugs are available in the nursing home that will be powered by the generators. Any air beds, oxygen equipment and refrigerators should be transferred to these plugs.

## RN/Assisted Living PSW (D, E, N)

For power interruption, staff can utilize work cell phones. Any resident room/apartment has a phone which may be functioning.

## Maintenance

- ☐ For electrical emergencies or flood affecting the elevator areas, lock out elevator and lock out physio centre when emergencies affect Palvelukoti, Finlandiakoti or Lepokoti.
- ☐ In any emergency, the initial problem is dealt with on site (ie broken water main flooding one room) and outside parties are contacted as needed (contractors, city, gas company etc.). Refer to emergency phone numbers policy.